



State of Utah

JON M. HUNTSMAN, JR.
Governor

GARY R. HERBERT
Lieutenant Governor

Department of Administrative Services

RICHARD K. ELLIS
Executive Director

Division of Facilities Construction and Management

F. KEITH STEPAN
Director

ADDENDUM # 1

Date: 08-22-2006

To: Contractors

From: Wayne Smith, Project Manager, DFCM

Reference: RTI Classrooms 9, 10, 11, 12
Camp Williams, Draper, Utah
DFCM Project #: 05236480

Subject: **Addendum No. 1**

Pages:	Addendum Cover	1 Page
	Architects Attachment	1 Pages
		2 Pages

Note: This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

1.1 Addendum Cover Sheet

1.2 Architects Attachment

End of Addendum



ajc architects

addendum
01

RTI Classrooms 9, 10, 11, 12

Camp Williams, Draper, Utah

DFCM Project #: 05236480

ajc architects project #: 0547

date: Tuesday, August 22, 2006
time: 2:05 PM

pages: 1

The bidders on the above captioned project shall be governed by the following changes, additions, and/or deletions in the Drawings and Specifications. This Addendum shall be included as part of the Contract Documents.

Item 1.1 ALTERNATE BID No. 1.

Refer to Specification Section 01230 ALTERNATES for requirements for bidding Additive Alternate No.1, for asphalt paving as indicated on the drawings.

Item 1.2 South Valley Sewer District Fees.

All fees accessed by South Valley Sewer District are to be included in the Base Bid.

See attached fee letter from South Valley Sewer District dated July 31, 2006.

Item 1.3

South Valley Sewer District requirements.

All South Valley Sewer District requirements for the project are to be met, as follows:

1. All sanitary sewer construction shall comply with South Valley Sewer District's Design Standards and Construction Specifications. Refer to District's website, www.southvalley.dst.ut.us.
2. Four feet of cover will be required over all sewer lines.
3. All applicable Sewer District fees must be paid.

END OF ADDENDUM

Kent R. Rigby, AIA

attachments: Specification Section 01230 ALTERNATES
Sewer District Fee letter.